

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERIFICATE

No. 2976 / जल परीक्षण / 23 Dated: 21/04/25

It is certified that an inspection team headed by Sunil Kumar Singh (A.E)

from U.P Jal Nigam (Rural), Mirzapur inspection the Vindhya Gyan Public School,

Company Ghat Road Devparwa, Mirzapur Uttar Pradesh on date 19/04/2025 and on the

basis of Water Test Report (Attached) bearing No. M2C7665 dated 29/03/2025 of District

Level Water Analysis Laboratory UP Jal Nigam (Rural), Mirzapur-UP (India) certified that

the Vindhya Gyan Public School has safe drinking water facilities for the students and

members of staff of the institution. School also maintains the hygienic sanitation condition in

the school buiding & the campus as per norms prescribed by the Central/State/U.T. Govt.

This Certificate is valid till 28/03/2026

Signature with seal:


सहायक अभियन्ता

खण्ड कार्यालय, उ० प्र० जल निगम (ग्रामीण)
Name: Sunil Kumar Singh

Designation: Assistant Engineer (A.E)

Name & Address of the Office/Department: UP jal Nigam (Rural) ,Mirzapur, Office of the
Executive Engineer Scarcity Division, Gandhi ghat, Bathua, Mirzapur (U.P) -231001

To

Vindhya Gyan Public School,
Company Ghat Road Devparwa,
Mirzapur Uttar Pradesh



District Level Water Analysis Laboratory

U.P Jal Nigam (Rural), Dist. Mirzapur



* TEST REPORT *

Name & Address of Customer: VINDHYA GYAN PUBLIC SCHOOL, DEVPARAWA, BALLIPARAWA, MIRZAPUR, U.P.			Customer Reference No.		No: 119/MZP/29 Dated: 29/03/2025	
			Sample Submitted by		Mr. Gyan Shankar	
			Date of Sample Receipt		29/03/2025	
			Analysis Starting Date		29/03/2025	
			Analysis completion Date		29/03/2025	
Discipline: Chemical Testing			Group: Water			
Test Report No.:		MBC7669	Date of Issue:		29/03/2025	
Registration no.:		DWTL/MZP/244/24	Condition of Sample:		Unsealed	
Source:		NA	Quantity/Type of Bottle:		1000ml / Amber Colored Glass Bottle	
Scheme:		NA	Location/Depth:		RO plant VINDHYA GYAN PUBLIC SCHOOL, DEVPARAWA, BALLIPARAWA, MIRZAPUR, U.P.	
Village:		DEVPARAWA	Habitation:		NA	
Block: -		BALLIPARWA	District:		MIRZAPUR	
Latitude:		NA	Longitude:		NA	
Sample Type: Treated Water						
Sr. No	Parameter	Result	As per 15-10500:2012 (2 nd Rev.)		Unit	Reference Method:
			Acceptable Limit	Permissible Limit		
1	pFI	7.75	6.5-8.5	No Relaxation		IS 3025 (Part 11-1993) Electrometric Method
2	Colour	01	5	15	Hazen	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Disagreeable		IS 3025 (Part 5 -2018) (Second Revision)
4	TDS	280	500	"2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Turbidity	0.19	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
6	Alkalinity	12	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
7	Hardness	120	200	600	mg/l	I63025 (Pan 21- 2019) EDTA Method
8	Calcium	27	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	13	30	100	m\$/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	88	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition:

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed)
5. * Value not available or test not performed for this parameter.

Dr. Shalendra Yadav
Quality Manager
Authorized Signatory
For, Regional Water Analysis,
Laboratory Jan Nigam Mirzapur- UP.